

BRIEF TECHNICAL SPECIFICATION FOR
10 WAY MICRO CONTROLLER BASED SEQUENTIAL TIMER CARD

1. ITEM	10 WAY Micro Controller Base Sequential Timer Card
2. MODEL	MpS1WD-9#1
3. APPLICATION	TO PROVIDE TIMED SEQ. ENERGISATION OF PILOT SOLENOID VALVE
4. DETAIL OF CONTROLLER (PCB)	
4.1 INPUT SUPPLY	110V AC or 220V AC *, 50 or 60 Hz.
4.2 INPUT FUSE (ENCLOSED TYPE)	1 Amp. 110, 220V AC, (GLASS 20mm)
4.3 ON TIME	20 TO 200 MILLISECONDS
4.4 OFF TIME	2 TO 60 SECONDS.
4.5 NUMBER OF SEQ. STEPS	1 TO 10 ADJ. through Flying Lead
4.6 TEMP. RANGE OPERATION	0 TO 55o C
4.7 CURRENT RATING PER SEQ.:	
a) MAXIMUM INRUSH CURRENT	10 Amps.
b) MAX. CONTINUOUS CURRENT	2 Amps. [1", 2 Nos. (Max. of Solenoid Valves per channel **)]
4.8 MAINS ISOLATION SWITCH	PROVIDED ON PCB
4.9 ON DEMAND CONTROL (PRESSURE SW. CONTACT)	PR. SW. TERMINALS (P1, P2) SEQUENCE CONTROLLER STOPS WHEN CONTACT AT PR.SW. OPENS. (PR. LED GLOWS, & CLOCK LED STEADY ON) SEQ. CONTINUES FROM POINT WHERE IT HAD STOPPED, WHEN CONTACT RE-CLOSES.
4.10 LED VISUAL INDICATIONS:	
a) POWER ON INDICATION	1 No. LED (5mm - RED COLOR)
b) OUTPUT ON INDICATION	10 Nos. LED (5mm - RED COLOR)
c) ON DEMAND MODE	1No. LED (5mm - RED COLOR)
d) MANUAL PULSING	1No. LED (5mm - RED COLOR)
5. MANUAL PULSING	FACILITY PROVIDED (P.B. SW.)
6. FEED BACK RELAY	POTENTIAL FREE CONTACT, 5A @230 V AC
7. PCB DETAILS:	SINGLE SIDE, GREEN MASKED, IDENT, WITH ANTI CORROSIVE LOCTITE SPRAY COATING.
a) P.C.B. DIMENSIONS	215 (L) x 145mm (W)
b) P.C.B. MOUNTING SIZE	205(L) x 135(W) mm (MOUNTING HOLES 4 Nos. 4mm)
c) UL	APPROVAL 94V-OSL1
8. ENCLOSURE DETAILS	TYPE- IP-55, SIEMENS GREY POWDER COATED
(Optional Extra)	(MOC: M.S. CRCA 1.6 Thk.)
a) ENCLOSURE SIZE	300(W) x 300(H) x 135(D)mm or 300X400X205(D)
b) ENCLOSURE OVER ALL SIZE	380(W) x 365(H) x 150(D)mm
c) MOUNTING DIMENSIONS	330(W) x 220(H)mm, WALL MOUNTED. OR PLYCARBONATE TRANSPARENT LID 300 x250 x135
9. TEST CERTIFICATE	ONE COPY WITH EACH CONTROLLER
10. MAKE	X'CALIBUR AUTOMATION, PUNE-30

Note : * Supplied as 110V AC only or 220V AC only.

** Only Solenoid Makes of X'CALIBUR, ASCO, GOYEN CONTROLS, MECAIR AND AVCON must be used which are pulse duty Bag Filter application Solenoids.

