

		<b>X' CALIBUR AUTOMATION</b> 26,'VIDHYESH' SENADUTTA PETH PUNE - 411 030.(INDIA) 020-24392381,24338284
		E-mail: <a href="mailto:xcalibur@eth.net">xcalibur@eth.net</a> , <a href="mailto:inlandsys@eth.net">inlandsys@eth.net</a>
	TECHNICAL SPECIFICATION FOR PNEUMATIC VIBRATORY SYSTEM (3 WAY)	
1	ITEM	VIBRATORY CONTROL SYSTEM
2	TYPE	COMBINED SYSTEM WITH SOLENOID & TIMER
3	APPLOCATION	GIVE PULSE TO VIBRATOR
4	SUPPLY VOLTAGE	24 V DC, +/- 10%
5	AMBIENT TEMPRATURE	55 DEG. C.
6	ENCLOSURE DETAILS OF VIBRATOR CONTROL SYSTEM	
6.1	SHEET THICKNESS	1.6mm THICK CRCA, SHEET STEEL
6.2	ENCLOSURE CLASS	IP-55 WITH CANOPY, WALL MOUNTING
6.3	ENCLOSURE SIZE	520 (H) x 475 (W) x 175mm(D) or as SUITABLE
6.4	COLOUR	SIEMENS GRAY, POWDER COATED
7	INSIDE PANEL ITEMS	
7.1	SEQUENTIAL TIMER	3 WAY MICRO CONTROLLER BASED RELAY TYPE
	7.1 INPUT & OUTPUT VOLTAGE	110/230VAC/ 24V DC
	7.2 ON TIME	10 TO 90 SEC. (ADJUSTABLE)
	7.2 OFF TIME	10 TO 3600 SEC. (ADJUSTABLE)
	7.3 MAKE	X'CALIBUR AUTOMATION
7.2	SOLENOID VALVE	
	7.2.1 SIZE	1/4" BSP, ONE WAY DIAPHRAGM TYPE
	7.2.2 INPUT VOLTAGE	110/230VAC/24 V DC,
	7.2.3 QUANTITY	3 Nos.
	7.2.3 MAKE	X'CALIBUR AUTOMATION
7.3	FRL UNIT	1/4" BSP,
	7.3.2 MAKE	PNEUMAX (ITELY)
	7.3.1 PRESSURE GAUGE	0-10 BAR
7.4	ISOLATION VALVE	1/4" BSP
	7.4.1 MAKE	STAR (ITELAY)
7.5	OTHERS	
	7.5.1 1/4" BSP AL. CONNECTORS	12 Nos.
	7.5.2 INPUT TERMINALS	3 Nos., CUT 4 TERMINALS
	7.5.3 GLAND	3/4" DOUBLE COMPRESSION GLAND - 1 No.
8	HARDWARE	
	8.1 TUBING (OD. Dia. 8mm x ID 6mm) M.O.C.: PU	30 Mtrs. BUNDEL TUBING SHOULD BE SUPPLIED AS LOOSE IN ONE BUNDLE., THESE SHALL BE CUT SITE AS PER SITE REQUIREMENT.
9	ORERING DETILS	1 No. 3 WAY VIBRATOR CONTROL SYSTEM & HARDWARE AS MENTIONED IN THIS SPEC.

